



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23015

1. OWNER Mike & Betty DoBosh ADDRESS AT WELL LOCATION 77 Sharon Dr
 MAILING ADDRESS 77 Sharon Dr Wellington, Nv 89447 Lot 21
 2. LOCATION NW 1/4 SE 1/4 Sec. 29 T 12 N/S R 23 E Lyon County Lyon
 PERMIT NO. 9-022-03 - Foothill Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
All broken & fractured loose decomposed granite		159	295	136
Bottom 20 feet filled with broken decomposed granite cuttings				
T.D. 276 feet				

8. WELL CONSTRUCTION
 Depth Drilled 295 Feet Depth Cased 276 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 3/8 Inches 160 Feet To 295 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.62	.188	9	276

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 196 feet to 216 feet
 From 256 feet to 276 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal refer to original log Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 156 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 4/5/93 19____
 Date completed 4/7/93 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	15		2 1/2
Larry Odgen Bros - Test pumped at 50+ GPM			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L
Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By-driller performing actual drilling on site or contractor
 Date 4/7/93

93 MAY 21 10:22
 RECEIVED
 STATE ENGINEERS OFFICE