

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11651

1. OWNER TRACY TOMAS ADDRESS AT WELL LOCATION Highway 308
 MAILING ADDRESS P.O. Box 773 Yearnington NV
Yearnington NV 89447
 2. LOCATION NW 1/4 NW 1/4 Sec. 11 T. 12 N/S R. 25 E Lyon County
 PERMIT NO. 12-271-01 Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel		0		20
gravel		20		40
gravel		40		60
gravel	✓	60		80
gravel	✓	80		100
gravel	✓	100		110

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>1.88</u>	<u>0</u>	<u>110</u>

Perforations:
 Type perforation Factory Slot
 Size perforation 3/32 x 3
 From 90 feet to 110 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 110 feet

9. WATER LEVEL
 Static water level 60' feet below land surface
 Minimum flow 20+ gpm G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started FEB 25-92, 19____
 Date completed FEB 28 92, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+ gpm</u>	<u>10'</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Emolco Contractor
 Address Box 92 Smith NV 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T
 Signed Jeff Steele
 By driller performing actual drilling on site or contractor
 Date March 2, 1992

'93 MAY 26 AM 10:39
 RECEIVED
 STATE ENGINEERS OFFICE