WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41862
Permit No.
Basin 137B

NOTICE OF INTENT NO. 18408

1. OWNER Round Mtn Gold
MAILING ADDRESS 1 Smokey Valley Mtn Rd
ADDRESS AT WELL LOCATION 1 Smokey Valley Mtn Rd.

2. LOCATION NE 1/4 NW 1/4 Sec. 24 T. 10 N N/S R. 43 E. Nye County
PERMIT NO. M/O 574A Issued by Water Resources
T-10 NR43E Parcel No.
Round Mtn Gold Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Perc Hammer

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravel + Cobbles		0	23	23
Calicha, Gravel + Sand		23	36	13
Sand + Gravel		36	64	28
Sand Gravel + Calicha		64	91	27
Hard Granite		91	98	7
Cobbles, Sand + Gravel		98	114	16
Sand + Gravel		114	119	5
Cobbles, Sand + Gravel		119	138	19
Sand + Gravel		138	162	24
Granite Cobbles, Sand + Gravel		162	223	61
Silty Clay + Cobbles		223	254	31
Silty Clay + Gravel		254	278	24
Sand + Gravel		278	285	7
Silty Clay, Gravel + Cobbles		285	300	15

Date started 5-15, 1993
Date completed 5-25, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 1/2		Sched 80	0	300

Perforations:
Type perforation Factory Slotted
Size perforation .020
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 57.4'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 232 feet to 300 feet

9. WATER LEVEL
Static water level 251.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Env Services (Contractor)
Address 9002 S. Hardy Dr. (Contractor)
Tempe Az. 85284
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1682
Signed (By driller performing actual drilling on site or contractor)
Date

JUN 11 P 2:48
STATE ENGINEER

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627