WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41869
Permit No.
Basin 179

NOTICE OF INTENT NO. 23226

1. OWNER Cecil & Lois WEAVER
MAILING ADDRESS HC 33 Box 33510 Ely NV 89301
ADDRESS AT WELL LOCATION McGill Hwy - 145 no. St.

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 17 N/S R. 63 E. WHITE Pine County
PERMIT NO. NA. Issued by Water Resources | 10-290-31 Parcel No. | NONE Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
Cemented gravel Cobbles		1	50	
Lime Stone		50	52	
Cemented gravel Cobbles		52	90	
gravel	water	90	91	1
Clay		91	93	
Cemented gravel		93	95	
Clay		95	97	
Cemented gravel		97	98	
Clay		98	102	
Sand gravel	water	102	105	3
Clay		105	115	
gravel main	water	115	120	5
Cemented gravel		120	125	
Clay		125	127	
gravel	water	127	128	1
Clay		128	133	
gravel	water	133	138	5
Clay		138	140	

RECEIVED JUN -2 '93 AM 11:25 STATE ENGINEERS OFFICE

Date started March 22, 1993
Date completed May 24, 1993

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	10	1

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	140 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation mill
Size perforation 4 x 2½ x 6 row
From feet to feet
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard Contractor
Address Po Box 176 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard By driller performing actual drilling on site or contractor
Date May 27-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627