



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10895

1. OWNER Richard Collett ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 SW 1/4 Sec 36 T. 19S N/S R. 52 E Nye County \_\_\_\_\_  
PERMIT NO. 28-231-11 Parcel No. \_\_\_\_\_ Subdivision Name Bell Vista Unit 2

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Caliche		4	6	2
Clay		6	21	15
Caliche		21	23	2
Clay		23	53	30
Caliche	WB	53	57	4
Clay		57	68	11
Caliche	WB	68	71	3
Clay		71	84	13
Caliche	WB	84	87	3
Clay		87	109	22
Caliche	WB	109	111	3
Clay		111	120	9
Caliche	WB	120	124	4
Clay		124	136	12
Caliche	WB	136	140	4

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>16.44</u>	<u>1.188</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Factory Saw Cut  
Size perforation 1/8" x 3"  
From 100 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No 140  
From 50 feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 48 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Great Basin Drilling Contractor  
Address HCR 78 Box 80358 Contractor  
Pahrump NV 89011  
Nevada contractor's license number issued by the State Contractor's Board 30880  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
Signed Thomas D...  
By driller performing actual drilling on site or contractor  
Date 7-5-93

Date started 6-21 1993  
Date completed 6-25 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED

JUL 13 1993

Div. of Water Resources  
Branch Office - Las Vegas, NV