


OFFICE USE ONLY  
Log No. 41884  
Permit No. \_\_\_\_\_  
Basin 16a



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10901

1. OWNER Tim Brey ADDRESS AT WELL LOCATION Gally St  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SE 1/4 DW 1/4 Sec 28 T 19S N 33 E Nye County  
PERMIT NO. 24-907-30 Parcel No. Bell Vista 3 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
caliche		8	10	2
Clay		10	36	26
caliche		36	40	4
Clay		40	72	32
caliche	WB	72	75	3
Clay		75	90	15
caliche	WB	90	92	2
Clay		92	111	19
caliche	WB	111	114	3
Clay		114	134	20
caliche	WB	134	137	3
Clay		137	152	15
caliche	WB	152	154	2
Clay		154	177	23
caliche	WB	177	181	4
Clay		181	192	11
caliche	WB	192	194	2
Clay		194	200	6

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 200 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.44</u>	<u>-.188</u>	<u>0</u>	<u>200</u>

Perforations:  
Type perforation factory saw cut  
Size perforation 1/8"  
From 160 feet to 280 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 200 feet

9. WATER LEVEL  
Static water level 68 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6-21 1993  
Date completed 6-25 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
Address HCR 78 Box 86358 Contractor  
Phinney NV 89041  
Nevada contractor's license number issued by the State Contractor's Board 36880  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
Signed Thomas Dan  
By driller performing actual drilling on site or contractor  
Date 7-6-93

RECEIVED

JUL 13 1993

Div. of Water Resources  
Branch Office - Las Vegas, NV