


Log No. 41890

Permit No. \_\_\_\_\_

Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11789

1. OWNER James Hal Fincher ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec 34 T. 19-S N/S R. 53 E Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources 49 Parcel No. \_\_\_\_\_ Subdivision Name Gerald Martin ROS

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Sandy Clay		4	30	26
Brown Clay		30	72	42
Gravel	x	72	78	6
Grey Clay		78	102	24
Hard Lime		102	111	9
Grey Clay		111	122	11
Brown Clay /Some				
Gravel	x	122	160	38

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	<u>18 lbs.</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation Torch Cut  
 Size perforation 3/4 in width 8 in long  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 OCT 01 1992  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

Date started Sept. 21 1992  
 Date completed Sept. 23 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>4</u>	<u>1/3</u>	

9. WATER LEVEL  
 Static water level 69 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor  
 Address St. Rt. Box 36525 Contractor

Nevada contractor's license number issued by the State Contractor's Board 7484  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date Sept. 28, 1992

