WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41891
Permit No.
Basin 162

NOTICE OF INTENT NO. 10898

1. OWNER Ralph Palumbo
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NE ¼ Sec. 1 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-552-03 (Parcel No.) Golden Springs Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Caliche		7	10	3
Clay		10	21	11
Caliche		21	23	2
Clay		23	44	21
Caliche		44	46	2
Clay		46	53	7
Caliche	WB	53	56	2
Clay		56	71	15
Caliche	WB	71	73	2
Clay		73	84	11
Caliche	WB	84	87	3
Clay		87	106	19
Caliche	WB	106	108	2
Clay		108	130	22
Caliche	WB	130	132	2
Clay		132	140	8

RECEIVED
JUL 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-21, 1993
Date completed 6-25, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HC68 Box 80358 Pahrump (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam (By driller performing actual drilling on site or contractor)
Date 7-6-93

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (D)-627