



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10414

1. OWNER LARRY WHITE ADDRESS AT WELL LOCATION MARK ST
MAILING ADDRESS _____

2. LOCATION NE 1/4 SW 1/4 Sec 12 T 20S N/S R 52 E Nye County _____
PERMIT NO. 28-851-09 Parcel No. _____ Subdivision Name GARY B & MONA HAFER PARCEL

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	15
Caliche		15	17	2
Clay		17	29	12
Caliche		29	33	4
Clay		33	56	23
Caliche	WB	56	58	2
Clay		58	74	16
Caliche	WB	74	76	2
Clay		76	93	17
Caliche	WB	93	96	3
Clay		96	111	15
Caliche	WB	111	114	3
Clay		114	131	17
Caliche	WB	131	133	2
Clay		133	140	7

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>3 5/8</u>	<u>16.99</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation Factory Sawcut
Size perforation 1 7/8 x 3
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

RECEIVED

OCT 01 1992

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-22, 1992
Date completed 9-25, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor
Address HEP 78 Box 80358 Contractor
Pahrump NV 89041

Nevada contractor's license number 30880 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dun
By driller performing actual drilling on site or contractor
Date 9-28-92