

Log No. 41902
 Permit No. _____
 Basin 1162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12039

1. OWNER Kings Land Development ADDRESS AT WELL LOCATION Hardy Ln
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SE 1/4 Sec 14 T. 20S N/S R S2 E Nye County _____
 PERMIT NO. 28-743-01 Parcel No. _____ Subdivision Name Charleston Park
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	7	7
Caliche		7	9	2
Clay		9	22	13
Caliche		22	25	3
Clay		25	36	11
Caliche		36	38	2
Clay		38	57	19
Caliche	WB	57	61	4
Clay		61	81	20
Caliche	WB	81	84	3
Clay		84	102	18
Caliche	WB	102	104	2
Clay		104	118	14
Caliche	WB	118	120	2
Clay		120	135	15
Caliche	WB	135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.44</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1 1/8 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address Hce 78 Box 80368 Contractor
Phonp NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Du
 By driller performing actual drilling on site or contractor
 Date 6-29-93

Date started 6-25 1993
 Date completed 6-29 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED

JUL 02 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

