


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



1. OWNER Kings Land Development ADDRESS AT WELL LOCATION Pueblo St.
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SE 1/4 Sec 21 T. 20S N/S R. 32 E Nye County _____
 PERMIT NO. 28-752-04 Parcel No. _____ Subdivision Name Charleston Park
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	4	4
Caliche		4	6	2
Clay		6	17	9
Caliche		17	19	2
Clay		19	37	18
Caliche		37	40	3
Clay		40	51	11
Caliche	WB	51	54	3
Clay		54	68	14
Caliche	WB	68	72	4
Clay		72	96	24
Caliche	WB	96	98	2
Clay		98	111	13
Caliche	WB	111	115	4
Clay		115	132	17
Caliche	WB	132	134	2
Clay		134	140	6

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/8 x 3/8
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HC R 78 Box 80358 Contractor
Palmer NV 89041
 Nevada contractor's license number 30680
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources the on-site driller
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 6-29-93

Date started 6-28 1993
 Date completed 6-29 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED

JUL 02 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV