WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41912
Permit No.
Basin

NOTICE OF INTENT NO. 12036

1. OWNER Kings land Development
MAILING ADDRESS
ADDRESS AT WELL LOCATION Pueblo St

2. LOCATION NW ¼ SE ¼ Sec. 24 T. 20 N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-752-04 (Parcel No.) Charleston park (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	16	10
Calichie		16	19	3
Clay		19	31	12
Calichie		31	35	4
Clay		35	57	22
Calichie	WB	57	61	4
Clay		61	76	15
Calichie	WB	76	78	2
Clay		78	83	5
Calichie	WB	83	85	2
Clay		85	101	16
Calichie	WB	101	103	2
Clay		103	125	22
Calichie	WB	125	128	3
Clay		128	134	6
Calichie	WB	134	140	6

RECEIVED
JUL 02 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-26, 1993
Date completed 6-29, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches	Feet	0 Feet	140 Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HC 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 6-29-93

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627