

Log No. 41951

Permit No. _____

Basin _____

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11996

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER JOHN RAINAS ADDRESS AT WELL LOCATION VICKI ANN & FREMONT ST.
MAILING ADDRESS _____

2. LOCATION SW 1/4 NE 1/4 Sec 14 T. 21 S. N/S R. 53 E. NYE County
PERMIT NO. 44-632-15 LOT 3 STARDUST Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
CALICHE		8	12	4
CLAY		12	20	8
CALICHE		20	32	12
CLAY		32	47	15
CALICHE		47	53	6
CLAY		53	58	5
CALICHE	WB	58	64	6
CLAY		64	77	13
CALICHE	WB	77	85	8
CLAY		85	99	14
CALICHE	W.B	99	105	6
CLAY		105	115	10
CALICHE	W.B	115	140	25

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Feet To 140 Feet
12 1/4 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 8 INCH BY 3 INCH
From 140 feet to 120 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING Contractor
Address HCR. 78 BOX 80358 Contractor
PA HUMP NV. 89041 Contractor
Nevada contractor's license number 30880 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Mannie Brown
By driller performing actual drilling on site or contractor
Date 9-30-92

Date started 9-11, 1992
Date completed 9-30, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
OCT 01 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

