

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.349

Log No. 41963
 Permit No. 1163
 Basis 1163
 NOTICE OF INTENT NO. 10504

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Richard Morgan ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS Box 3005 Star Route
42-89124
 2. LOCATION SE 1/4 SW 1/4 Sec. 20 T. 22 N/S R. 58 E Clark County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fractured Limestone			0	130
Hard Limestone			130	150
Limestone & Clay & Water			150	170
Fractured Limestone			170	460
Limestone & Water	xx		170	505

8. WELL CONSTRUCTION
 Depth Drilled 505 Feet Depth Cased 505 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0	55
9 7/8" Inches	55	505

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 7/8"	16.94	.188	+1	505

 Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 460 feet to 480 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED

OCT 14 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 7/7/92, 19_____
 Date completed 7/15/92, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 1.05 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey Pine
Las Vegas, Nevada 89102
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed Vernon H. Dimick
 By driller performing actual drilling on site or contractor
 Date 10/13/92