



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12025

1. OWNER ED KOLOJAY ADDRESS AT WELL LOCATION JUSKEGEE & EMERALD SANDY VALLEY NV.
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec. 22 T. 24 S. N/S R. 56 E. CLARK County
 PERMIT NO. 580-160-103 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	8	8
CALICHE		8	12	4
CLAY		12	22	10
CALICHE		22	28	6
CLAY		28	36	8
CALICHE		36	41	5
CLAY		41	58	17
CALICHE		58	68	10
CLAY		68	77	9
CALICHE		77	86	9
CLAY		86	108	22
CALICHE	W.B.	108	115	7
CLAY		115	122	7
CALICHE	W.B.	122	128	6
CLAY		128	140	12

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

 Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 8 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

RECEIVED

JUL 13 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-29, 1993
 Date completed 6-31, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR. 78 BOX 80358 Contractor
LAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Annie Brown
 By driller performing actual drilling on site or contractor
 Date 7-5-93

