WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41965
Permit No.
Basin 163

NOTICE OF INTENT NO. 12026

1. OWNER ED KOLOJAY
MAILING ADDRESS
ADDRESS AT WELL LOCATION TUSKEGEE & EMERALD
SANDY VALLEY NV.

2. LOCATION SW ¼ NW ¼ Sec 22 T 24S N/S R 56 E CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-160-102 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	8	8
CALICHIE		8	12	4
CLAY		12	22	10
CALICHIE		22	28	6
CLAY		28	36	8
CALICHIE		36	41	5
CLAY		41	58	17
CALICHIE		58	68	10
CLAY		68	77	9
CALICHIE		77	86	9
CLAY		86	108	22
CALICHIE	W.B.	108	115	17
CLAY		115	122	7
CALICHIE	W.B.	122	128	6
CLAY		128	140	12

RECEIVED
JUL 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-28, 1993
Date completed 6-31, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dennis Brown
By driller performing actual drilling on site or contractor
Date 7-5-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627