

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12049

1. OWNER JOHN + PEGGY ELLENBERG ADDRESS AT WELL LOCATION EMERALD + SHOSHONE SANDY VALLEY
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec 22 T. 24 S N/S R. 56 E CLARK County
 PERMIT NO. 580-160-092 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CALICHE		6	8	2
CLAY		8	38	30
CALICHE		38	44	6
CLAY		44	58	14
CALICHE		58	61	3
CLAY		61	88	27
CALICHE		88	92	4
CLAY		94	106	12
CALICHE	W.B.	106	112	6
CLAY		112	122	10
CALICHE	W.B.	122	129	7
CLAY		129	140	10

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 9/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 5 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

RECEIVED
 JUN 13 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 89 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 6-28, 1993
 Date completed 6-31, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR 78 BOX 80358 Contractor
LAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-5-93