



Log No. 41971
 Permit No. _____
 Basin 163

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

11/30/00

NOTICE OF INTENT NO. 12044

1. OWNER DONALD DAVIS ADDRESS AT WELL LOCATION SANDY VALLEY
 MAILING ADDRESS _____

2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 24 N/S R. 56 E. CLARK County
 PERMIT NO. 580-240-103 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	7	7
CALICHE		7	12	5
CLAY		12	28	16
CALICHE		28	33	5
CLAY		33	53	20
CALICHE		53	56	3
CLAY		56	59	3
CALICHE	W.B.	59	64	5
CLAY		64	72	8
CALICHE	W.B.	72	76	4
CLAY		76	90	14
CALICHE	W.B.	90	95	5
CLAY		95	114	19
CALICHE	W.B.	114	122	8
CLAY		122	134	12
CALICHE	W.B.	134	138	4
		138	140	2

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 3 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

RECEIVED
 JUL 02 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

Date started 6-22 1993
 Date completed 6-25 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR. 78. BOX 80358 Contractor
PAHRUMP NV. 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, then-site driller 1573
 Signed Dennis Brown
 By driller performing actual drilling on site or contractor
 Date 6-26-93