WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41980
Permit No.
Basin 164A

NOTICE OF INTENT NO. 9714

1. OWNER Marvin Lester
MAILING ADDRESS P.O. Box 19457
Jean, Nev. 89019

ADDRESS AT WELL LOCATION
Goodsprings

2. LOCATION NE ¼ SE ¼ Sec 26 T 24 N/S R 58 E Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown silt & gravel | | 0 | 11 | 11 |
| cemented conglomerate | | 11 | 13 | 2 |
| yellow silty clay, gravel | | 13 | 18 | 5 |
| fractured yellow lime stone | | 18 | 34 | 16 |
| redish brown clay & gravel | | 34 | 58 | 24 |
| yellow fractured limestone | | 58 | 80 | 22 |
| red clay | | 80 | 85 | 5 |

RECEIVED
NOV 04 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-27, 1992
Date completed 10-28, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 50+ | ? | 1 |

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)
10 Inches 0 From Feet 85 To Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8" | 12.92 | .188 | +1 | 85 |

Perforations:
Type perforation Torch
Size perforation 3/16 x 6 x 4 around
From 50 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916-0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed (By driller performing actual drilling on site or contractor)
Date 11-2-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627