



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1.0509

1. OWNER Frank Smaka ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS N/A

2. LOCATION SW 1/4 SW 1/4 Sec 7 T 19S N/S R 59 E Clark County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel and Boulder		0	250	
Gravel & Water	X	250	255	
Hard Cemented Gravel		255	380	
Hard Limestone		380	400	
Black Limestone		400	405	
Limestone		405	410	
Cream Colored Limestone		410	415	
Bright Yellow Rock		415	430	
Limestone & Water	x	430	467	

8. WELL CONSTRUCTION
 Depth Drilled 467 Feet Depth Cased 467 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 1/4" Inches 0 Feet 55 Feet
9 7/8" Inches 55 Feet 467 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 7/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>467</u>

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 427 feet to 447 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 365 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey Pines Contractor
Las Vegas, Nevada 89102
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V.H. Dimick
 By driller performing actual drilling on site or contractor
 Date 10-24-92

Date started 9/16/92, 19____
 Date completed 9/30/92, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 OCT 29 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

