

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 41984
 Permit No. _____
 Basin _____
 NOTICE OF PATENT NO8381

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER MatHEW Bernard ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Same 7000 Rome Blvd.
Las Vegas, Nev 89131
 2. LOCATION NW 1/4 SE 1/4 Sec. 22 T. 19S N/S R. 60 E. Clark County _____
 PERMIT NO. 105-22-704-008 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Popcorn Caliche | | 0 | 18 | |
| Caliche | | 18 | 24 | |
| Clay | | 24 | 50 | |
| Caliche | | 50 | 56 | |
| Clay | | 56 | 180 | |
| Caliche & Water | xx | 180 | 186 | |
| Clay | | 186 | 250 | |
| Caliche | | 250 | 265 | |
| Clay | | 265 | 420 | |
| Clay & Water | | 420 | 460 | |

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 460 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4" Inches 0 Feet 460 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8 5/8"</u> | <u>16.94</u> | <u>.188</u> | <u>+2</u> | <u>460</u> |

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 420 feet to 440 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 255 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 255 feet to 460 feet

9. WATER LEVEL
 Static water level 1.73 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey pines Contractor
Las Vegas, Nev. 89102
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V.H. Dimick
 By driller performing actual drilling on site or contractor
 Date 10/13/92

Date started August 20, 1992, 19____
 Date completed September 1, 1992, 19____

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | |
|--|-------------------------------|--------------|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| | | |
| | | |
| | | |
| | | |

RECEIVED
 OCT 14 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

