

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10957

1. OWNER Jim Hubert ADDRESS AT WELL LOCATION 5th & Lemont
 MAILING ADDRESS 495 Goldfield
NLD NV 89031
 2. LOCATION NE 1/4 SE 1/4 Sec 34 T 19 N R 61 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>White Clay</u>		<u>0</u>	<u>145</u>	<u>145</u>
<u>Bn Claystone</u>	<u>X</u>	<u>145</u>	<u>170</u>	<u>25</u>
<u>Bn Clay</u>		<u>170</u>	<u>195</u>	<u>25</u>
<u>Bn Claystone</u>	<u>X</u>	<u>195</u>	<u>300</u>	<u>105</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 300
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8"</u>		<u>.188</u>	<u>+1</u>	<u>300</u>

Perforations:
 Type perforation Joseph
 Size perforation 1/4" X 8"
 From 220 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 ft
 Placement Method: Pumped Poured
 Resources packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 87 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mitchell Enterprises Contractor
 Address 630 Remy Contractor
NV NV 89124
 Nevada contractor's license number issued by the State Contractor's Board 27030
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1495
 Signed Dean Mitchell
 By driller performing actual drilling on site or contractor
 Date June 24, 1993

Date started June 21, 1993
 Date completed June 24, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>607</u>	<u>450 CFM @ 300 ft.</u>	

RECEIVED
 JUL 06 1993
 Div. of Water Resources
 Branch Office - Las Vegas NV

