

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 42607
 Permit No. _____
 Basin 212
 NOTICE OF INTENT NO. 9025

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Emelio Ygnietzi ADDRESS AT WELL LOCATION Wicki
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 Sec 19 T 22 N 61 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Boulders & Clay</u>		<u>5</u>	<u>220</u>	<u>215</u>
<u>Cemented gravel</u>	<u>X</u>	<u>220</u>	<u>290</u>	<u>70</u>
<u>Clay w/ gravel layers</u>	<u>X</u>	<u>290</u>	<u>375</u>	<u>85</u>

8. WELL CONSTRUCTION
 Depth Drilled 375 Feet Depth Cased 375 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4" To 375 Feet
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>.188</u>	<u>±1</u>	<u>375</u>

Perforations:
 Type perforation Yorch
 Size perforation 1 1/4" x 8"
 From 375 feet to 375 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat-Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 375 feet

9. WATER LEVEL
 Static water level 225 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mitchell Enterprises Contractor
 Address 630 Beatty Contractor
Las Vegas N.V. 89129
 Nevada contractor's license number issued by the State Contractor's Board 27030
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
 Signed Dean Mitchell
 By driller performing actual drilling on site or contractor
 Date 6-16-93

Date started 5-18, 1993
 Date completed 6-15, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40 to 50</u>		<u>Pumped 2 hrs</u>

RECEIVED
 JUL 06 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV