



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9712

1. OWNER Wanda P. Morgan ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3801 Highway #146 Pyle Dr. West  
Las Vegas, Nev. 89124

2. LOCATION SW 1/4 NE 1/4 Sec 29 T 22 N/S R 61 E Clark County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt sand gravel		0	7	7
calechi		7	9	2
silt sand & gravel		9	42	33
gravel		42	69	27
cemented sand & gravel		69	84	15
sand & gravel		84	110	26
cemented sand & gravel		110	114	4
sand & gravel		114	118	4
clay sand & gravel		118	140	22
sand & gravel		140	175	35
red clay sand & gravel		175	180	5
sand & gravel		180	213	33
cemented sand & gravel		213	228	15
clay sand & gravel		228	252	24
sand & gravel		252	269	17
clay sand & gravel		269	288	19
cemented sand & gravel		288	300	12

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	300

Perforations:  
 Type perforation Torch  
 Size perforation 3/16" x 6 x 4 around  
 From 160 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 145 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc. Contractor  
 Address 4847 So. Valley View Blvd. Contractor  
Las Vegas, Nev. 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916/0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald Walker  
 By driller performing actual drilling on site or contractor  
 Date 9-16-92

Date started 9-4 1992  
 Date completed 9-10 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-22</u>	<u>?</u>	<u>2</u>

RECEIVED  
 SEP 25 1992  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

