WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42012
Permit No.
Basin 212

NOTICE OF INTENT NO. 10510

1. OWNER Alexander A. Dobritch
MAILING ADDRESS 7855 S. Procyon 89118
ADDRESS AT WELL LOCATION N/A

2. LOCATION NW ¼ SE ¼ Sec. 6 T 23 N/S R 61 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
Lime Stone		5	80	
Reddish Clay & Limestone		80	90	
Limestone		90	95	
Reddish Clay Limestone		95	105	
Hard Limestone		105	295	
Cream Colored limestone		295	300	
and water	xx			
Hard limestone		340	390	
limestone & water	xx	390	400	
Hard limestone		400	430	
Limestone & Water	xx	430	455	

RECEIVED
OCT 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10/2/92, 19
Date completed 10/9/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4"	Inches	0 Feet	55 Feet
9 7/8"	Inches	55 Feet	455 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	455

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 415 feet to 435 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 270 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nev 89118
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed (By driller performing actual drilling on site or contractor)
Date 10/13/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627