

OFFICE USE ONLY
 Log No. 42023
 Permit No. _____
 Basin 6-88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21670

1. OWNER RON VUCOVICH ADDRESS AT WELL LOCATION 155 Del Mesa Cir.
 MAILING ADDRESS 14025 Prairie Reno, NV 89511
 2. LOCATION SE 1/4 NW 1/4 Sec. 9 T. 17N N/S R. 1920 E. Washoe County
 PERMIT NO. 017-350-20 Steamboat area
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SITE # 2.				
Fill		0	2	2
Clay mixed w/rock		2	7	5
Reddish brown clay (brittle)		7	30	23
Gray-brown sandy clay		30	44	14
Gray rock, med.		44	58	14
Grayish pink clay		58	76	18
Brown clay		76	90	14
Orangish brown clay w/volcanic rock		90	105	15
Brown clay w/volcanic rock		105	131	26
Volcanic rock		131	152	21
Yellow tan clay w/volcanic rock		152	170	18
Pinkish gray clay w/volcanic rock	X	170	188	18
Broken fractured rock	X	188	217	29
Hard rock		217	224	7
Brown rock/soft	X	224	228	4
Tan brown rock med.	X	228	247	19
Black rock w/soft streaks	X	247	270	23
Brown clay		270	288	18
Brown tan rock w/soft streaks		288	299	11
Rock hard		299	320	21

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
10	0	50	Feet
8 5/8	50	220	Feet
6 1/8	220	320	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"		.188	0	220
5"		.188	200	320

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 160 feet to 220 (6") feet
 From 220 feet to 240 (5") feet
 From 280 feet to 320 (5") feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow 12 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

Date started 5-26-93, 19____
 Date completed 6-2-93, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number issued by the 908 Division of Water Resources the on-site driller
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date June 15, 1993