

OFFICE USE ONLY  
 Log No. 22029  
 Permit No. \_\_\_\_\_  
 Basin 6-89

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23024

1. OWNER Rex & Sylvia Tuttle ADDRESS AT WELL LOCATION 395 Flicker Cr  
 MAILING ADDRESS 395 Flicker Cr Lot 32 Block F  
Carson City, Nv 89704

2. LOCATION NW 1/4 NW 1/4 Sec 5 T. 16 N/S R 20 E Washoe County  
 PERMIT NO. 50-413-33 - New Washoe City # 5  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan brown red yellow & white sands & gravels		95	225	130
Tan clay		225	232	7
Coarse sands & gravels brown white yellow green with tan		232	273	41
T.D. 273 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 273 Feet Depth Cased 273 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/2 Inches To 95 Feet  
273 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.62	.188	73	273

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 243 feet to 273 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal refer to original log  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 86 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 5/26/93

Date started 5/25/93, 19\_\_\_\_  
 Date completed 5/25/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>