WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42034
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 24220

1. OWNER Leon Reynolds
MAILING ADDRESS 265 W Coyote New Washo City
ADDRESS AT WELL LOCATION 265 Coyote

2. LOCATION SW ¼ NE ¼ Sec. 31 T 17 N/S R 20 E Washo County
PERMIT NO. Issued by Water Resources
Parcel No. 50-385-15
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	8	8
Course Sands		8	35	27
Green Clay Seams		35	55	20
Brown Sandy Clay		55	87	32
Silty Sand		87	107	20
D.G.		107	145	38
Fracture No Water		145	147	2
Hard Course D.G.		147	170	23
Fracture 4 G.P.M	x	170	176	6
D.G.		176	185	9
Hard Granite With Fracture	xxx	185	260	75

Date started 6-18, 1993
Date completed 6-21, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	40	1 hr

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11½ Inches	0 Feet	185 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.03	.188	0	185

Perforations:
Type perforation 3/32 X 3 1/2
Size perforation Mill Slot
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 185 feet

9. WATER LEVEL
Static water level 35' feet below land surface
Artesian flow G.P.M. 60 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO
Contractor
Address 5551 Hwy 50 East ... son City, Nevada 8... 0459
Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6/21/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627