

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24246

1. OWNER GARY HEMBREE ADDRESS AT WELL LOCATION 2373 Beaver Lane Carson City NV. (KINOH HILLS)
MAILING ADDRESS 306 Ruby Ln. Carson City NV.
2. LOCATION SW 1/4 SW 1/4 Sec. 23 T. 15 S. R. 20 E. CARSON County
PERMIT NO. 10-11-01 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>11</u>	<u>11</u>
<u>Shales</u>		<u>11</u>	<u>41</u>	<u>30</u>
<u>Gravels w/ Clay seams</u>		<u>41</u>	<u>91</u>	<u>50</u>
<u>Gravels w/ clay seams + small seams DG.</u>		<u>91</u>	<u>120</u>	<u>29</u>
<u>Gray clay w/ seams of DG. etc.</u>		<u>120</u>	<u>160</u>	<u>40</u>

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet
HOLE DIAMETER (BIT SIZE)
From 11 1/4 Inches To 160' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.03</u>	<u>.188</u>	<u>0</u>	<u>160'</u>

Perforations:
Type perforation Mill shot
Size perforation 3/2 x 3/32
From _____ feet to _____ feet
From 140' feet to 160' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100' Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 100 feet to 160' feet

Date started 6/23, 1997
Date completed 6/24, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>60</u>	<u>2</u>

9. WATER LEVEL
Static water level 30' feet below land surface
Artesian flow _____ G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO
5551 Hwy. 50 East
Address Carson City, Nevada
885-0459 Contractor
885-1888 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quanton R. Hubbs
By driller performing actual drilling on site or contractor
Date 6/25/93