

OFFICE USE ONLY #1  
 Log No. 42042  
 Permit No. \_\_\_\_\_  
 Basin 8-103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20773

1. OWNER CARSON CITY ADDRESS AT WELL LOCATION CARSON CITY DUMP (LANDFILL)  
 MAILING ADDRESS CITY HALL CARSON CITY, NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 1 T. 15 S. R. 21 E. CARSON CITY County  
 PERMIT NO. \_\_\_\_\_ Parcel No. NONE Subdivision Name NONE  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ANDESITE TUFF		0		
VITROPHERE				
META VOLCANICS	X	420	420	

193 JUN 28 AM 11:07  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 420 Feet Depth Cased 420 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 280 Feet  
 6 3/4 Inches 280 Feet 420 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	-	.188	+2	280
5 1/16	-	.188	252	420

 Perforations:  
 Type perforation SAUCNT  
 Size perforation 3X 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 252 feet to 410 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 80 FT  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 80 feet to 280 feet  
 9. ? WATER LEVEL  
 Static water level ? feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality ?

Date started 5/17 1993  
 Date completed 6/14 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30±</u>	<u>?</u>	<u>6 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC. Contractor  
 Address Box 21548 Contractor  
CARSON CITY, NV 89721  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller  
 Signed Joe Reisch  
 By driller performing actual drilling on site or contractor  
 Date 6/17/93