WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42048
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 10013

1. OWNER Bud Wykoff
MAILING ADDRESS 8605 Santa Fay Stage Coach NV. 89429
ADDRESS AT WELL LOCATION 8605 Santa Fay, Stage Coach NV.

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) | C-3 15-432-21 | NA (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Some Brown Clay		0	15	
Brown Clay		15	60	
Brown Clay and Gravels		60	93	
Gravels		93	115	
Gray Clay		115	130	
Some Gravel and Brown Clay		130	145	
Coarse Gravels		145	160	

Date started 7/15 1993
Date completed 7/16 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 3 Hours and produced about 25 Gallons/min		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11"	0	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
11"	13.00	3/16	+1	160

Perforations:
Type perforation Mill Perf
Size perforation 3/16 X 1 X 5 Rows
From 120 feet to 160 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leacht Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-15-93

RECEIVED JUL 20 '93 AM 11:21 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627