WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42049
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 10016

1. OWNER Gene Saccone prop.
MAILING ADDRESS 6165 Shetland Stage Coach NV. 89429
ADDRESS AT WELL LOCATION 6165 Shetland Stage Coach NV. 89429

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 19-382-36 (Parcel No.) Rancho Sub-#3 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay And Soil | | 0 | 20 | 20 |
| Boulders and Some Gravels | | 20 | 85 | 65 |
| Gray Clay | | 85 | 105 | 20 |
| Some Fine Gravel and Clay | | 105 | 120 | 15 |
| Coarse Gravels | ✓ | 120 | 130 | 10 |

'93 JUL 21 A10:58
STATE ENGINEER

Date started 6/28/93, 1993
Date completed 6/29/93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Developed For 3 Hours And Produced about 10 Gallons 4 min | | | |

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 11" Inches | 0 Feet | 130 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.00 | 3/16 | +1 | 130 |

Perforations:
Type perforation Air Perf
Size perforation
From 100 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CEACH Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed [signature] By driller performing actual drilling on site [illegible]
Date 7/15/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(9)-627