

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20845

1. OWNER David Davis ADDRESS AT WELL LOCATION Alleeman Ln - Old Foothill rd. Gard. NV
MAILING ADDRESS 201 E Ocean Blvd. Long Beach, Calif. 90802
2. LOCATION SW 1/4 NE 1/4 Sec 3 T. 12 N/S R. 19 E Douglas County
PERMIT NO. 19-060-34 Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------------------|-------------------------------------|------------|------------|------------|
| <u>06 top soil SAND</u> | | <u>0</u> | <u>40</u> | |
| <u>Coarse DG SAND</u> | <input checked="" type="checkbox"/> | <u>40</u> | <u>90</u> | |
| <u>SAND & Small rock</u> | | <u>90</u> | <u>145</u> | |
| <u>SAND</u> | | <u>145</u> | <u>200</u> | |
| <u>SAND & ROCKS</u> | | <u>200</u> | <u>240</u> | |
| <u>SAND & SILTS</u> | | <u>240</u> | <u>335</u> | |
| <u>SANDSTONE</u> | | <u>335</u> | <u>365</u> | |
| <u>SAND & Rock fragments</u> | | <u>365</u> | <u>400</u> | |

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 400 Feet
9 7/8 Inches.....
.....Inches.....
.....Inches.....

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 7/8</u> | <u>12.5 lbs</u> | <u>.88</u> | <u>0</u> | <u>400</u> |

Perforations:
Type perforation factory & hand cut
Size perforation 3" x 5/16"
From 400 feet to 360 feet
From 200 feet to 220 feet
From.....feet to.....feet
From.....feet to.....feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 400 feet to 100 feet

9. WATER LEVEL
Static water level.....feet below land surface
Artesian flow 3+ G.P.M. P.S.I.
Water temperature Cold °F Quality.....

Date started 7-9 1993
Date completed 7-17 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|--------------|-------------------------------|------------------|
| <u>AIR</u> | <u>15-20</u> | | <u>3 1/2 hrs</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchuck Drilling Inc. Contractor
Address P.O. Box 1359 Contractor
Minden, NV 89423
Nevada contractor's license number #02068 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, then site driller #495
Signed Michael Collier
By driller performing actual drilling on site or contractor
Date 7-17-93

'93 JUL 30 AM 10:3
STATE ENGINEER (U.F.)