WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42060
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 20859

1. OWNER Gary Peterson
MAILING ADDRESS P.O. Box 2126 Gard NV
ADDRESS AT WELL LOCATION 1576 E Valley Rd. ~~Min~~ Gard. NV.

2. LOCATION NW ¼ SE ¼ Sec. 26 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-295-26 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Sand		0	10	
Gravel		10	25	
Clay & Gravel		25	55	
Clay & Sand	X	55	65	
Clay Sand & Gravel		65	95	
Sand		95	105	
Sand & Gravel		105	135	
Clay Sand & Gravel		135	170	
Gravel & Sand	XX	170	190	
Clay Sand & Grav		190	200	
Gravel & Sand	XX	200	220	
Clay Sand & Gravel		220	230	
Gravel & Sand	XX	230	240	

'93 JUN 24 AM 11:10
STATE ...

Date started 5-24, 1993
Date completed 5-27, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	30+	—	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.5 lbs	.188	0	240

Perforations:
Type perforation Factory Perf
Size perforation 3" x 5/32"
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 240 feet to 100 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling Inc. (Contractor)
Address 2668 Fuller Minden NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen (By driller performing actual drilling on site or contractor)
Date 5-28-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627