

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22375

1. OWNER VINCE McALLA ADDRESS AT WELL LOCATION 1574 MILKWEED CT
 MAILING ADDRESS 1574 MILKWEED CT GARDNERVILLE, NV 89410
 2. LOCATION S W 1/4 SE 1/4 Sec. 36 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. APN 23-473-40 Parcel No. lot 13 B Subdivision Name WILDFLOWER

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY BRN CLAY & DEBBLES		0	30	
" " " GRAVELS		30	68	
SANDY BRN CLAY		68	77	
" " " GRAVELS		77	118	
SANDY BRN CLAY		118	124	
SANDY BRN CLAY w GRAV		124	177	
SANDY BRN CLAY w SAND		177	204	
SANDY BRN CLAY		204	290	
" " " w COARSE SAND		290	304	
SH GRV. w SANDY BRN CLAY WB	WB	304	318	
SANDY BRN CLAY		318	327	
SH GRV. w SANDY BRN CLAY WR	WR	327	353	
SANDY BRN CLAY		353	365	
SH GRV. w SANDY BRN CLAY WB	WB	365	400	

JUL 16 AM 12:20
 '93 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cascd. 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 1/8" Inches 0 Feet 400 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188'	0'	400'

Perforations:
 Type perforation FACTORY
 Size perforation 3/32" x 3"
 From 396' feet to 356' feet
 From 356' feet to 336' feet BLANK
 From 400' feet to 396' feet BLANK
 From 336' feet to 316' feet FACT
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50' feet to 400' feet

9. WATER LEVEL
 Static water level 175' feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature WARM Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address Box 92 Contractor
SMITH, NV 89444
 Nevada contractor's license number 32166
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Sherald W. Phinnell
 By driller performing actual drilling on site or contractor
 Date 7-13 93

Date started 6-29, 1993
 Date completed 7-7, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>	<u>175'</u>	<u>7 HR.</u>