

OFFICE USE ONLY
 Log No. 42063
 Permit No. _____
 Basin. B-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20PS1

1. OWNER Dan Edmonds ADDRESS AT WELL LOCATION 1588 BARKER RD. GARD NU. 89410
 MAILING ADDRESS Box 273 Gard NU 89410

2. LOCATION NE 1/4 NW 1/4 Sec. 31 T. 13 N/S R. 21 E Douglas County
 PERMIT NO. 23-170-13 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name Fish Springs

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & TOP SOIL		0	20	
CLAY & SAND		20	30	
SAND & GRAVEL		30	50	
CLAY & SAND		50	60	
CLAYS		60	130	
SAND	X	130	160	
CLAY		160	180	
CLAY & GRAVEL		180	195	
CLAY		195	275	
CLAY & GRAVEL		275	285	
CLAY SAND & GRAVEL		285	300	
CLAY SILT & BLACK SAND	X	300	325	

'93 JUN 24 AM 1:10
 RECEIVED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 325 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.5 lbs</u>	<u>R/R</u>	<u>0</u>	<u>325</u>

Perforations:
 Type perforation Freeport Feet
 Size perforation 3" x 15/32"
 From 300 feet to 325 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 325 feet to 50 feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/5 1993
 Date completed 5/13 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>207</u>	<u>-</u>	<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kauchack Drilling Inc. Contractor
 Address 2668 Fuller Minden Nu Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1380
 Signed Michael Allen By driller performing actual drilling on site of contractor
 Date 5/14/93