

OFFICE USE ONLY
Log No. 42065
Permit No. 8-105
Basin 8-105
NOTICE OF INTENT NO. 24243

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BLADES CONSTRUCTION ADDRESS AT WELL LOCATION 3474 ALPINE VIEW
MAILING ADDRESS BOX 1273
GARDNERVILLE, NV 89410
2. LOCATION NE 1/4 SW 1/4 Sec. 11 T. 14 N. R. 9 E Douglas County
PERMIT NO. 15-080-37 ALPINE VIEW ESTATES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY DG.		0	28	28
SANDY DG. some clay		28	45	17
SANDY AND GRAVEL	✓	45	48	3
D.G.		48	65	17
D.G. w/some gravel		65	72	7
Semi hard Granite		72	130	58
Fractured Granite	✓	130	137	7
Granite w/some fractures	✓	137	190	53

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet
HOLE DIAMETER (BIT SIZE)
From To
1 1/4 Inches 0 Feet 60 Feet
8 3/4 Inches 60 Feet 190 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 11.7 .188 +2 190
Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" X 3"
From 170 feet to 190 feet
From 130 feet to 150 feet
From 60 feet to 70 feet
Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 50' Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 50 feet to 190 feet
9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality good

Date started 7/29, 1993
Date completed 8/6, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>55</u>		<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AT H Pump Co Contractor
Address 555 Highway 50C #3 Contractor
Carson City, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450
Signed [Signature]
By driller performing actual drilling on site or contractor
Date Aug 9, 1993