

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24244

1. OWNER El Camino Development ADDRESS AT WELL LOCATION 6777 Saddlehorn Dr  
 MAILING ADDRESS 501 S. Carson St Carson City, NV 89701 Carson City, NV 89701  
 2. LOCATION SW 1/4 NW 1/4 Sec. 4 T. 14 N. R. 20 E. Carson City County  
 PERMIT NO. 09-711-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name None

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Ran drill string into well and tagged bottom of well at 163 feet. Pulled out of well and ran perforator in casing and perforated casing from 1' to 163', removed perforator and ran treemie pipe, (1 1/2"), to bottom of well. Mixed up a mixture of neat cement and water and pumped mixture into well and displaced the water. Pumped mixture until the returns were thick grout and then removed the treemie pipe. Topped of seal that had settled. 7/6/93: Returned to site and topped off well again. It had settled about 8 feet.				
Total bags of cement placed: 75				
NOTE: Unable to retrieve casing due to outer concrete seal.				

8. WELL CONSTRUCTION  
 Depth Drilled 163 Feet Depth Cased 163 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	13.5	.188	0	163

Perforations:  
 Type perforation Casing perforator  
 Size perforation 1/2" 1" at 6" intervals  
 From 1 feet to 163 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 163'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 69 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/5/93, 19\_\_\_\_  
 Date completed 7/6/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO. Contractor  
 Address 5551 Hiway 50 E, Unit 3 Contractor  
Carson City, NV 89701  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472  
 Signed Quinton R. Ruff  
 By driller performing actual drilling on site or contractor  
 Date 7-5-93