WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42074
Permit No.
Basin 9-107

NOTICE OF INTENT NO. 23469

1. OWNER MR WEAVER
MAILING ADDRESS LAZY W RANCHES
510 HY 338 WELLINGTON NV 89444
ADDRESS AT WELL LOCATION 210 WELLINGTON CUT OFF
WELLINGTON NV 89444

2. LOCATION S ½ ¼ ¼ Sec. 17 T. 10 N/S R. 24 E/W Lyon County
PERMIT NO. Issued by Water Resources | APN 10 741 22 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND SOME GRAVEL		0	18	
SANDY CLAY W/SM. GRVLS		18	59	
BOULD. MIXED SANDY CLAY		59	65	
GRVL W SANDY CLAY		65	85	
BOULD W/SANDY CLAY		85	105	
SANDY CLAY W GRVL		105	112	
BOULD. W/SANDY CLAY		112	118	
SANDY CLAY W/SM. GRVLS		118	143	
BOULD. W/SANDY CLAY		143	158	
SANDY CLAY W/SM GRVLS		158	190	
BOULD. W/SANDY CLAY		190	204	
SANDY CLAY W GRVLS		204	215	
GRVL W SOME SANDY CLAY	WB	215	240	

Date started 6 30, 1993
Date completed, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	160	6 HR

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
9 7/8"	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	240

Perforations:
Type perforation FACTORY
Size perforation 3/32" X 3"
From 240' feet to 236' feet BLANK
From 236' feet to 216' feet FACT.
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 100 feet to 240 feet

9. WATER LEVEL
Static water level 180' feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER Contractor
Address BOX 92 Contractor
SMITH, NV 89444
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-26-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627