WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42095
Permit No.
Basin 9-107

NOTICE OF INTENT NO. 22379

1. OWNER Tom WAFLEY
MAILING ADDRESS
ADDRESS AT WELL LOCATION UPPER COLONY RD. SMITH NV 89444

2. LOCATION NE ¼ SW ¼ Sec. 4 T. 11 (N)/S R. 23 (E) LYON County
PERMIT NO. (Issued by Water Resources) APN 10 361 01 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	
DG W/BRN SANDY CLAY		1	41	
SANDY BRN CLAY		41	47	
DG W/BRN SANDY CLAY		47	95	
SMGRVL W/SANDY CLAY		95	125	
DG W/BRN SANDY CLAY		125	192	
BRN SANDY CLAY W/DG		192	202	
DG W/SOME SANDY BRN CLAY WB		202	237	
BRN SANDY CLAY W/DG		237	240	

'93 JUL -6 P2:03
STATE ENGINEER

Date started 6-1, 1993
Date completed 6-8, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+		5 HR.

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 240 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	240

Perforations:
Type perforation FACTORY
Size perforation 3/32" x 3"
From 240 feet to 220 feet
From 220 feet to 200 feet T.C.
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 118 feet below land surface
Artesian flow G.P.M. 35+ P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address BOX 92 (Contractor)
SMITH, NV 89444
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald W. Plummell (By driller performing actual drilling on site or contractor)
Date 6-11-93

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627