



Log No. 42084
 Permit No. _____
 Basin 9-108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Elmo Aylor ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 498 Hwy 208
Yerington NV 89447
 2. LOCATION SW 1/4 SW 1/4 Sec. 2 T. 12 N. R. 25 E. T40N County _____
 PERMIT NO. 12-261-07 12-261-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____
 Municipal/Industrial Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Sandy Clay		3	4	1
Brick Clay		4	15	11
Coarse Sand & Small Gravel		15	31	16
Coarse Sand & Gravel		31	118	87
Small Rock		118	160	42'

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 161 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.105</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation Sawed
 Size perforation 3 1/2" x 6 Rows
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Good °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. Bybee Lane Contractor
Yerington Nev
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-28-93

Date started Nov 5 1992
 Date completed Nov 5 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>25</u>	<u>52</u>	<u>1/2</u>

JUN 29 11:29 AM '93
 STATE ENGINEERS OFFICE