

OFFICE USE ONLY  
 Log No. A2086  
 Permit No. 9-108  
 Basin 1

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER FRED Batchelder ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 484 Hwy 208  
Yerington Nev 89447  
 2. LOCATION SW 1/4 SW 1/4 Sec 2 T. 12 S. R. 25 E. Lyon County  
 PERMIT NO. 12-261-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Clayish		0	3	3
Sandy Clay		3	4	1
Brown Clay		4	15	11
Coarse Sand & Small Gravel		15	31	16
Coarse Sand & Gravel		31	40	9
Coarse Sand & Gravel & Rock		40	118	78
Coarse Sand & Gravel	X	118	146	28

'93 JUN 29 P1:30  
 STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 146 Feet  
 HOLE DIAMETER (BIT SIZE)  
16 7/8 Inches From FD Feet To 145 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>11</u>	<u>145</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 3/32 x 3/8" x 6 Rows  
 From 125 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 145 feet

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started Oct 28, 1992  
 Date completed Oct 31, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>35</u>	<u>6</u>	<u>1/2</u>
<u>Air</u>	<u>100+</u>	<u>100' air line</u>	<u>2 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N. Bybee Lane Contractor  
Yerington Nev 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Lo Ogden  
 \_\_\_\_\_ By driller performing actual drilling on site or contractor  
 Date 6-28-92