WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42087
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 20490

1. OWNER Edward + Jennifer Probst
MAILING ADDRESS 32 Sunny Grove Yerington Nev.
ADDRESS AT WELL LOCATION 32 Sunny Grove Drive Yerington Nevada

2. LOCATION NW ¼ SW ¼ Sec. 9 T. 12 N/S R. 25 E. Lyon County
PERMIT NO. none (Issued by Water Resources) 12-231-43 (Parcel No.) Sunny Grove (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
large rock + T.D.G.		0	12	12
brown fine sand + clay mix		12	87	75
gravel with some sand	yes	75	120	45
sandy clay	yes	120	125	5
hard layer rock		125	137	12
gravel, coarse + rock	yes	137	155	18

Date started July 29, 1993
Date completed Aug 2, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	5 ft	3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
6 Inches		60 Feet	155 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	155

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 x 3
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 92 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Aug 7 1993

AUG 11 '93 P2:35 STATE ENGINEERS OFFICE

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627