

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19141

1. OWNER Curtis A. Weir ADDRESS AT WELL LOCATION 14 Locust
 MAILING ADDRESS 4838 Spell Ave Yerington Nev 89447
San Jose Calif 95136

2. LOCATION NE 1/4 NE 1/4 Sec. 6 T. 13 N. S. R. 25 E. Lyon County
 PERMIT NO. 04-157-21 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil (Sand-Rock)		0	5	5
Vol. Fill Course Sand-Gravel-Rock		5	10	5
Vol. Fill Course Sand-Gravel-Clay		10	12	2
Vol. Fill Course Sand-Gravel		12	38	26
Vol. Fill Course Sand-Gravel-Rock		38	58	20
Vol. Fill Course Sand-Gravel-Rock-Clay		58	94	36
Strata		94	128	34
Vol. Fill Course Sand-Gravel	X	128	139	11
Vol. Fill Course Sand-Gravel-Rock	X	139	159	20

8. WELL CONSTRUCTION
 Depth Drilled 159 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 159 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.72</u>	<u>.100</u>	<u>71</u>	<u>159</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/8" x 3" x 6 Rows
 From 139 feet to 159 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 159 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. Pybee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Ag. Ogden
 By driller performing actual drilling on site or contractor
 Date 6-28-93

Date started Mar 1 1993
 Date completed Mar 5 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailor</u>	<u>30</u>	<u>15</u>	