

OFFICE USE ONLY
 Log No. 42089
 Permit No. _____
 Basin 9-108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER R.N. Fulstone ADDRESS AT WELL LOCATION 4 Purser Lane
 MAILING ADDRESS P.O. Box 61 Yerington Nev 89447
Smith Nev 89403
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T 13 N R 25 E 1/4 County _____
 PERMIT NO. 12-191-21
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other UNKNOWN

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Place neat Cement</u>				
<u>From 60' to Top</u>				
<u>No water flow over top of well</u>				
<u>16 Bags Poured</u>				
<u>2' Standing water at time of pour</u>				

8. WELL CONSTRUCTION
 Depth Drilled 60 Feet Depth Cased 60 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>1.56</u>	<u>0</u>	<u>60</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started Sept 24, 1992
 Date completed Sept 24, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Poor

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. Py Bee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Leg Ogden
 By driller performing actual drilling on site or contractor
 Date 6-28-93