WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42090
Permit No.
Basin 9-108

NOTICE OF INTENT NO.

1. OWNER R.N. Falstone
MAILING ADDRESS P.O. Box 61 Smith Nev 89430
ADDRESS AT WELL LOCATION 4 Parsel Lane Yerington Nev 89447

2. LOCATION SE ¼ SE ¼ Sec. 35 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 12-191-21 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sandy Clay		0	2	2
Clayish Sand		2	6	4
Coarse Sand		6	8	2
Brown Clay		8	15	7
Coarse Sand + Gravel		15	24	9
Clay + Sand		24	38	14
Coarse Sand + Gravel		38	47	9
Coarse Sand + Gravel + Small Rock		47	62	15
Coarse Sand + Rock		62	90	28
Coarse Sand + Clay		90	92	2
Coarse Sand + Gravel + Small Rock		92	115	23
Coarse Sand + Gravel + Clay		115	135	20
Coarse Sand + Gravel + Small Rock		135	138	3
Coarse Sand + Gravel	X	138	146	8
Coarse Sand + Gravel + Small Rock	X	146	147	1
Coarse Sand + Gravel + Clay Strates	X	147	158	11
Clay + Sand + Gravel		158	160	2
				92

Date started Sept 9, 19~~93~~ 92
Date completed Sept 13, 19~~93~~ 92

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	35	3	1/2

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 161 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	160

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3 x 6 Rows
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Jay Ogden (By driller performing actual drilling on site or contractor)
Date 6-28-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627