WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42091
Permit No.
Basin 9-108

NOTICE OF INTENT NO.

1. OWNER Tom Hamilton
MAILING ADDRESS 34 South Bybee
Yerington Nev 89447

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SW ¼ Sec. 2 T. 13 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) | Parcel No. 14-652-10 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil with Rock		0	6	6
Fill - Coarse Sand +				
Gravel + Rock - Tight		6	68	62
Fill - Coarse Sand +				
Gravel + Rock - Loose		68	104	36
Fill - Coarse Sand +				
Gravel + Rock - Tight		104	112	8
Fill - Coarse Sand +				
Rock + Clay - Tight		112	125	13
Fill - Coarse Sand +				
Rock - Loose	X	125	145	20
Fill - Coarse Sand +				
Gravel + Clay - Tight		145	154	9
Fill - Coarse Sand				
+ Rock - Loose	X	154	175	21
Fill - Coarse Sand +				
Clay - Tight		175	180	5
Fill + Coarse Sand +				
Rock - Loose	X	180	190	10
				92

Date started Sept 14, 19~~85~~ 92
Date completed Sept 17, 19~~85~~ 92

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	25	20	1/2

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 191 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	+1	190

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 190 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden (By driller performing actual drilling on site or contractor)
Date 6-28-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627