WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42092
Permit No.
Basin 9-108

NOTICE OF INTENT NO.

1. OWNER Lee Redmon
MAILING ADDRESS 1724 Virginia ave. West Sacramento, Calif. 95691
ADDRESS AT WELL LOCATION #20 Miley Road Yerington, Nev. 89447

2. LOCATION NW ¼ SW ¼ Sec. 3 T. 13 (N/S) R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) APN 14-641-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Coarse Sand		3	16	13
Clay - Coarse Sand - Gravel		16	23	7
Fine to Coarse Sand		23	30	7
Fine Sand - Clay		30	38	8
Clay - Fine Sand		38	43	5
Coarse Sand - Gravel		43	59	16
Coarse Sand - Gravel & Rock		59	65	6
Coarse Sand - Gravel		65	96	31
Fill - Coarse Sand Gravel - Rock - Clay		96	112	16
Fill - Sand - Gravel	X	112	118	6
Fill - Sand - Gravel Rock	X	118	126	8
Fill - Sand - Gravel	X	126	139	13
Fill - Sand - Clay		139	140	1

Date started 9-24, 1992
Date completed 9-28, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	35	52	1/2 HR

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	140

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 44' 6" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N Bybee Lane (Contractor) Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 2-24-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627