WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42914
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 19140

1. OWNER MELVIN V. SNODDY
MAILING ADDRESS 86 Butte Way
Yerington Nev 89447
ADDRESS AT WELL LOCATION 5 Penrose Lane
Yerington Nev 89447

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. 58092T - 58093T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic - Commercial ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Page 1

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Fine to Coarse Sand		3	16	13
Coarse Sand-Gravel		16	47	31
Clay-Coarse Sand		47	52	5
Fine to Coarse Sand		52	55	3
Clay-Small Gravel		55	78	23
Brown Clay		78	84	4
Coarse Sand-Gravel	—	84	114	30
Clay-Small Gravel		114	118	4
Fine to Coarse Sand-Clay		118	142	24
Fine to Coarse Sand-Small Gravel		142	160	18
Coarse Sand-Small Gravel-Clay		160	164	4
Coarse Sand-Small Gravel	—	164	175	11
Clay-Gravel		175	190	15
Coarse Sand-Small Gravel-Clay		190	222	32
Clay-Small Gravel		222	230	8
Coarse Sand-Clay		230	242	12
Clay-Gravel		242	245	3
Coarse Sand-Gravel-Clay		245	250	5
Clay-Fine Sand		250	300	50
Coarse Sand-Gravel-Clay Strata	—	300	330	30
Clay-Fine to Coarse Sand		330	348	18

Date started FEB 16, 1993
Date completed FEB 28, 1993

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	30	5"	½ HRS
Pump	100	25.5"	12 HRS

8. WELL CONSTRUCTION
Depth Drilled 381 Feet Depth Cased 382 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14" Inches		0 Feet	23 Feet
12¾ Inches		23 Feet	381 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	381

Perforations:
Type perforation Sawed
Size perforation 3/32 X 3" X 8 Rows
From 361 feet to 381 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 381 feet

9. WATER LEVEL
Static water level 28' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 North By Bee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date March 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42094
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 19140

1. OWNER MELVIN V. SNODDY
MAILING ADDRESS 86 Butte Way
Yerington Nev 89447
ADDRESS AT WELL LOCATION 5 Rinose Lane
Yerington Nev 89447

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 14 N/S R. 25 E. Lyon County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic - Commercial ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Page 2				
Coarse Sand -				
Small Gravel - Clay	✓	348	353	5
Clay - Gravel		353	360	7
Coarse Sand - Gravel -				
Small Rock	X	360	381	21

Date started Feb 16, 1993
Date completed Feb 28, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	30	5	½ HRS
Pump	100	25.5'	12 HRS

8. WELL CONSTRUCTION
Depth Drilled 381 Feet Depth Cased 382 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	23 Feet
12 3/4 Inches		23 Feet	381 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	381

Perforations:
Type perforation Sawed
Size perforation 3/32 X 3" X 8 Rows
From 361 feet to 381 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 361 feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 North Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date March 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627