WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42095
Permit No.
Basin 9-108

NOTICE OF INTENT NO.

1. OWNER Vince Dye
MAILING ADDRESS 120 Penrose Lane Yerington Nev 89447
ADDRESS AT WELL LOCATION 10 Kathleen Way Yerington Nev 89447

2. LOCATION NW ¼ NE ¼ Sec. 10 T. 14 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 14-221-25 Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clayish		0	4	4
Coarse Sand & Clay		4	16	12
Coarse Sand		16	23	7
Blue Clay & Sand		23	34	11
Blue-Gray Clay & Sand		34	38	4
Blue-Gray Sand		38	42	4
Brown Coarse Sand & Clay		42	49	7
Brown Sand		49	58	9
Blue-Gray Sand		58	61	3
Blue-Gray Sand-Clay		61	82	21
Brown Clay-Sand		82	106	22
Brown Clay-Coarse Sand		106	112	6
Brown Sand-Clay		112	116	4
Coarse Sand-Gravel	X	116	139	23
				92

Date started Oct 19, 19~~93~~ 92
Date completed Oct 23, 19~~93~~ 92

7. WELL TEST DATA

TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	25	5	½

8. WELL CONSTRUCTION
Depth Drilled 139 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	139

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	139

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 119 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 139 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor) Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-28-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627